

## **SECTION 8**

### **8.09 FROST:**

No pipe or appurtenant structure shall be installed upon a foundation into which frost has penetrated, or at any time when Denver Water deems there is danger of ice formation, or frost penetration at the bottom of the excavation. No pipe or appurtenant structure shall be installed unless backfilling can be completed before the formation of ice and frost.